



Regional Water Testing Laboratory
(Uttar Pradesh Jal Nigam, Gorakhpur)
Address: EWS 388,389,390 Rapti Nagar Phase-I, Medical Road,
Gorakhpur(U.P)-273003



TC-12931

Rept. No	92	CHEMICAL SAMPLE TEST REPORT		Page No
/Camp / Lab-1		Date:	18/07/2025	
Office Name and Address		Customer Details		
Ref Letter No & Date		14/07/2025		
Basic details of sample				
District	Gorakhpur	Block		
Gram Panchayat		Village		
Habitation		Location	SPM Global Academy, Bhatiyaree Khajni Gorakhpur	
Water Source	R.O	Sample Code	(C/25/07/03)	
Quantity of Sample	1000ml	Date of S.C.	14/07/2025	
Receiving Date	14/07/2025	S. Collector	S.M Pandey	
Sample Depositor	S.M Pandey		Analysis Completion Date	15/07/2025
Analysis Start Date	15/07/2025			

Environmental Condition

Temperature	26.2 °C	Relative Humidity	56%
-------------	---------	-------------------	-----

Technical Data of Analysis

Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Odour	Agreeable				IS 3025 (Part 5):2018
2	Turbidity	0.93	NTU	1	5	IS 3025 (Part 10):2023
3	pH (25°C)	7.32	--	6.5-8.5	No relaxation	IS 3025 (Part 11):2022
4	Total Dissolved Solids	88	mg/L	500	2000	IS 3025 (Part 16):2023
5	Total Hardness	68	mg/L	200	600	IS 3025 (part 21):2023
6	Total alkalinity	54	mg/L	200	600	IS 3025(Part 23):2023
7	Chloride as Cl ⁻	18	mg/L	250	1000	IS 3025(Part 32):2003
8	Calcium	28.8	mg/L	75	200	IS 3025(Part 40): 2024
9	Magnesium	8.96	mg/L	30	100	IS 3025(Part 46): 2023
10	Sulphate	3.212	mg/L	200	400	APHA 24th Edition 4500-SO ₄ Method E Turbidimetric Method 2023
11	Nitrate	0.243	mg/L	45	No relaxation	APHA 24th Edition 4500-NO ₃ Method B UV Screening Method 2023
12	Iron	0.052	mg/L	1	No relaxation	APHA 24th Edition 3500-Fe Method B Phenanthroline Methods 2023
13	Fluoride	0.322	mg/L	1.0	1.5	APHA 24th Edition 4500-F Method C (Electrode Method) :202300
14	Arsenic	BDL	mg/L	0.01	No Relaxation	APHA 24th Edition 3500 Method B (Silver Diethyldithiocarbamate Method)

#BDL- Below Detection Limit, NA- Not Analyzed

* Parameter(s) above permissible limit are in bold digits.

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless.
 5. Sample not collected by the laboratory.

Vishal Anand
Review By

MANAGER
SPM GLOBAL ACADEMY
Khajni, Gorakhpur

Authorized Signatory

Laboratory Contact details: Email-labgorakhpur@gmail.com

Contact - +91 8604561988

End of Report

Manager
S.P.M. PUBLIC SCHOOL
K. in Nagar, Chargawan
Gorakhpur (U.P.)

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

CERTIFICATE NO DATED: 92/camp/lab-1 Dated:- 18/07/2025

It is certified that an inspection team headed by Assistant Engineer, Shashank Pandey from U.P. Jal Nigam Gorakhpur inspected the SPM Global Academy, Bhatiyaree Khajni, Gorakhpur, on 14/07/2025 and on the basis of Water Test Report (Attached) bearing no 92/camp/lab-1 dated 18/07/2025 of District Water Analysis Laboratory Jal Nigam Gorakhpur (PHED Lab) certified that the SPM Global Academy Bhatiyaree Khajni, Gorakhpur, has safe drinking water facilities for the students and members of staff of the institution as per the norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till: 18/07/2025 to 17/01/2026

Counter
Vishal Pandey

Name:- Shashank Pandey

Assistant Engg

Designation:- Assistant Engineer

To,

Manager

SPM Global Academy Bhatiyaree Khajni,
Gorakhpur, 273406

MANAGER
S.P.M. GLOBAL ACADEMY
Bhatiyari, Khajani, Gorakhpur

Manager
S.P.M. PUBLIC SCHOOL
Karam Nagar, Chorgawan
Gorakhpur (U.P.)